



# TYPE-EXAMINATION CERTIFICATE

**Certificate No.:** G 589/2

**Certificate Holder:** Label S.p.A.  
Via Ilariuzzi 17/A  
S. Pancrazio P.se  
43126 Parma - Italy

**Manufacturer:** Label S.p.A.  
Via Ilariuzzi 17/A  
S. Pancrazio P.se  
43126 Parma - Italy

**Product:** Automatic sliding doors (with break-out fittings) in rescue ways, "EVOLUS" and "ETERNA" series

**Test laboratory:** TÜV SÜD Industrie Service GmbH  
Abteilung Aufzüge und Sicherheitsbauteile  
Gottlieb-Daimler-Str. 7  
70794 Filderstadt - Germany

**Test Report:** G 589/2 dated 2018-12-12

**Reference Standards:** AutSchR:Dez 1997 Directive for automatic sliding doors on escape and rescue routes  
EitVTR:Dez 1997 Directive on electric locking systems for doors on escape and rescue routes  
DIN 18650-1:2010-02 Powered pedestrian doors - Part 1: Product requirements and test methods  
DIN 18650-2:2010-02 Powered pedestrian doors - Part 2: Safety at powered pedestrian doors  
DIN EN 16005:2013 Power operated pedestrian doorsets – Safety in use – Requirements and test methods

**Outcome:** The swing-out sliding doors with "EVOLUS" and "ETERNA" drive system, meet the requirements of the test specifications for the respective scope of application stated in the annex to this type examination certificate. The conditions mentioned in the annex have to be observed.

**Date of Issue:** 2018-12-12

**Validity until:** 2023-12-11

Department Lifts and Safety Components

Peter Retzbach







**Annex to Type Examination Certificate  
No. G 589/2 of 2018-12-12**



Industrie Service

**3 Notices**

- 3.1 The electronic control system of the "EVOLUS" and "ETERNA" drive system meets category 2 and PL d according to EN ISO 13849-1.
- 3.2 An endurance test with more than 1.000.000 cycles has been carried out.
- 3.3 The essential product-relevant provisions of the standards DIN 18650-1:2010 and DIN 18650-2:2010 have been considered within this certification (application class 1 in rescue ways with swing-out fittings according to DIN 18650-1:2010 number 4.7).
- 3.4 Further requirements of the responsible authorities for buildings are not touched.
- 3.5 Issuing the EU declaration of conformity resp. fixing of the CE-mark in conformity with the Directive relating to machinery is under responsibility of the installer of the whole system "automatic sliding door" in consideration of the situation of each single door system (situation of the building, surrounding).
- 3.6 The type examination certificate G 589/2 is only to be passed on together with this annex.